



CERTIFICATE

B - 9077 - FD - K 1013 - version c

We certify that the multisensor detector

Apollo Fire Detectors Ltd SA5100-700

and the variants as described in the annexes,

complies with the following specifications:

Rules of the BOSEC mark:

Administrative and legal clauses;

Certification rules Products;

EN 54-5:2017/A1:2018;

EN 54-7:2018;

EN 54-17:2005/AC:2007;

Not under the scope of the BELAC-accreditation:

CEA 4021:2003;

based upon the following test reports of the laboratories ANPI and certificates:

BFS/REDI/568, ADD1, ADD2 & 2531-CPR-CSP10987.

*This certificate is only valid if the products are marked with the **BOSEC** label.*

The company

Apollo Fire Detectors Ltd.

36 Brookside Road

Havant

Hampshire PO9 1JR

United Kingdom

*is authorised to use the brand **BOSEC** on the above mentioned components.*

**The certificate is granted subject to the
BOSEC brand committee and ANPI terms
and conditions and is valid until**

signed on behalf of **ANPI**
Louvain-la-Neuve, 16 November 2022

31 August 2034


Marie-Jane
Certification Manager

asbl **ANPI** vzw - Association Nationale pour la Protection contre l'Incendie et l'Intrusion
Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve

cert@anpi.be www.anpi.be





Annex 1 to the certificate B - 9077 - FD - K 1013 - version c

Multisensor detector with short-circuit isolator

Apollo Fire Detectors Ltd SA5100-700 (class A1R)

manufactured at Havant, GB

Variants: Apollo Fire Detectors Ltd SA5100-700LIM (class A1R)

Apollo Fire Detectors Ltd SA5100-760 (class A1R)

Base

Apollo Fire Detectors Ltd SA5000-200

manufactured at Havant, GB

**This annex is an undivided part of the
BOSEC certificate and is valid until**

signed on behalf of **ANPI**
Louvain-la-Neuve, 16 November 2022

31 August 2034


Marie-Jeanne
Certification Manager

asbl **ANPI** vzw - Association Nationale pour la Protection contre l'Incendie et l'Intrusion
Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve

cert@anpi.be www.anpi.be

