



# CERTIFICATE

**B - 9077 - FD - K 1026 - version b**

*We certify that the fire detection component:*

OPTICAL SMOKE DETECTORS WITH SHORT-CIRCUIT ISOLATOR:  
APOLLO FL5100-600

Manufactured at Havant, United Kingdom

*complies with the following specifications:*

BOSEC Mark Rules:

Administrative and Legal Clauses & Certification rules Products ;  
EN 54-7:2000/A1:2002/A2:2006  
EN 54-17:2005

*based upon the test report of the laboratories ANPI & Certificate(s) of Constancy of Performance (CPR):*

BFS/REDI/579-2018.03.04. & 2531-CPR-CSP10950

*This certificate is only valid if the products are marked with the **BOSEC** label.*

*The company*

**Apollo Fire Detectors Ltd**  
**36 Brookside Road**  
**Havant**  
**Hampshire PO9 1JR**  
**United Kingdom**

*is authorised to use the brand **BOSEC** on the above mentioned components. An instruction manual shall be provided with each detector*

**The certificate is granted subject to the BOSEC brand committee and ANPI terms and conditions and is valid until**

signed on behalf of **ANPI**  
**Brussels, 06 February 2020**

**31 August 2022**

  
Secretary-General  
**T. DOUILLET**

asbl **ANPI** vzw - Association Nationale pour la Protection contre l'Incendie et l'Intrusion  
Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve  
**Tél:** +32 10 47 52 11 **Fax:** +32 10 47 52 70 [cert@anpi.be](mailto:cert@anpi.be) [www.anpi.be](http://www.anpi.be)



This certificate and the annexes may only be copied completely and without any alteration.

003-PROD ISO/IEC 17065