



CERTIFICATE

B - 9077 - FD - K 1019 - version b

We certify that the fire detection component:

INPUT-OUTPUT DEVICES WITH SHORT-CIRCUIT ISOLATOR:

APOLLO SA4700-100, APOLLO SA4700-103, APOLLO SA4700-104

Variants: APOLLO SA4700-102, APOLLO SA4700-300, APOLLO SA4700-302, APOLLO SA4700-403, APOLLO SA6700-100

Manufactured at Havant, United Kingdom

complies with the following specifications:

BOSEC Mark Rules:

Administrative and Legal Clauses & Certification rules Products ;

EN 54-17:2005

EN 54-18:2005

based upon the test report of the laboratories ANPI & Certificate(s) of Constancy of Performance (CPR):

BFS/REDI/575-29/05/2017. & 2531-CPR-CSP10991, 2531-CPR-CSP11049, 2531-CPR-CSP11050

*This certificate is only valid if the products are marked with the **BOSEC** label.*

The company

Apollo Fire Detectors Ltd

36 Brookside Road

Havant

Hampshire PO9 1JR

United Kingdom

*is authorised to use the brand **BOSEC** on the above mentioned components. An instruction manual shall be provided with each detector*

The certificate is granted subject to the BOSEC brand committee and ANPI terms and conditions and is valid until

12 July 2029

signed on behalf of **ANPI**
Brussels, 06 February 2020

Secretary-General
T. DOUILLET

asbl **ANPI** vzw - Association Nationale pour la Protection contre l'Incendie et l'Intrusion

Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve

Tél: +32 10 47 52 11 Fax: +32 10 47 52 70 cert@anpi.be www.anpi.be

