



Construction Products Regulation: EU (No) 305/2011

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

DECLARATION OF PERFORMANCE

No. D0006

1. Unique identification code of the product-type:

Model number and Description:

RW1000-700APO - REACH Heat and Smoke Detector using Radio Links

Approved Accessories:

n/a

Harmonised Product Type(s):

Heat detectors Smoke detectors Components using radio links

2. Intended use/es:

Point detectors for use in fire detection and fire alarm systems installed in and around buildings Fire detection and fire alarm systems installed in and around buildings

3. Manufacturer:

Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

4. Authorised representative:

Apollo Gesellschaft für Meldetechnologie mbH Am Anger 31 33332 Gütersloh Deutschland

5. System(s) of AVCP

System 1

6 Harmonised Standard(s)

EN 54-5:2017 + A1:2018 EN 54-7:2018 EN 54-25:2008 + AC:2012

Notified Body/ies:

IMQ ISTITUTO ITALIANO DEL MARCHIO DI QUALITÀ S.P.A. (Notified Body No. 0051)

A HALMA COMPANY 36 Brooksid







36 Brookside Road, Havant, Hampshire, PO9 1JR, UK t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

7. Declared performance

Essential characteristics	Clauses in EN 54-5:2017/ A1:2018	Regulatory classes	Performance
Operational reliability:			
Position of heat sensitive element	4.2.1		The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g. Characteristics correctors), are a distance ≥15mm from the mounting surface of the point heat detector.
Individual alarm indication	4.2.2		Category A1R The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector, in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.3		Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector
Monitoring of detachable point heat detectors	4.2.4		A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.5		It is not possible to change the manufacturer's settings except by special means (e.g. a special code or tool, or by breaking or remove a seal).
Onsite adjustments of response behavior	4.2.6		N/A
Software controlled detectors (when provided)	4.2.7	_	The software documentation and the software design complies supplied by the manufacturer with the requirements of this standard.
Nominal activation conditions/Sensitivity:		A1R	
Directional dependence	4.3.1		The response time of the point detector do not unduly depend on the direction of airflow around the point heat detector.
Static response temperature	4.3.2		The response temperatures of the point heat detectors lie between the minimum and maximum static response temperatures, according to the category of the point heat detector in Table 1 above.
Response times from typical application temperature	4.3.3		The response times of the point heat detector lie between the lower and upper response time limits for the appropriate point heat detector category in Table 2 above.
Response times from 25 °C	4.3.4		The response time at 3 K min ⁻¹ exceeds 7 min 13 s and the response time at 20 K min ⁻¹ exceeds 1 min 0 s.
Response times from high ambient temperature	4.3.5		No alarm or fault signal was given at high ambient temperatures appropriate to the anticipated service temperatures. A1R 3 K min ⁻¹ , Lower limit, 1 min 20 s and upper limit 13 m 40 s. 20 K min ⁻¹ , Lower limit, 12 s and upper limit 2 m 20 s.
Reproducibility	4.3.6		The response times of the point heat detectors lie between the lower and upper response time limits specified in Table 2 above.
Response delay (response time):			



Additional test for suffix S point	4.4.1	
heat detectors		N/A
Additional test for suffix R point heat detectors	4.4.2	Suffix R, the point heat detector maintains the response requirements of its category, in table 2 above, for high rates of rise of temperature from an initial temperature below the typical application temperature applicable to the category marked on it.
		Point heat detector Initial conditioning category temperature °C
		A1R 5±2
		AIN
Tolerance to supply voltage:		
Variation in supply parameters	4.5	The point heat detector does not unduly depend on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above.
Durability of nominal activation conditions/Sensitivity:		·
temperature resistance		
Cold (operational)	4.6.1.1	No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature
		A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Dry heat (endurance)	4.6.1.2	No fault signal was given on reconnection attributable to the endurance conditioning
		A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Humidity resistance	4.6.2.4	No shows a facility in a large shows the conditions
Damp heat, cyclic (operational)	4.6.2.1	No alarm or fault signal was given during the conditioning.
		Lower temperature: (25±3) °C Upper temperature: (40±2) °C
		Relative humidity:
		At lower temperature: ≥ 95 %
		At upper temperature: (93 ±3) %.
		A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Damp heat, steady-state (endurance)	No fault signal was given on reconnection attri- endurance conditioning.	
		Conditioning
		Temperature: 40 ±2 °C
		Relative Humidity: 93 ±3 %
		Duration: 21 days
		A1: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
		1



Corrosion resistance		
Sulphur dioxide (SO ₂) corrosion (endurance)	4.6.3	No fault signal was given on reconnection attributable to the endurance conditioning.
		Conditioning
		Temperature: 25 ±2 °C
		Relative Humidity: 93 ±3 %
		SO2 concentration: 25 ±5 ppm (by volume)
		Duration: 21 days
		AAD 20 K wis 1 was not been then 20 and did not award 20 a
		A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6
Vibration resistance		
Shock (operational)	4.6.4.1	No alarm or fault signal was given during the conditioning period or an additional 2 min.
		For specimen with a mass ≤ 4,75 kg:
		Shock pulse type: Half sine
		Pulse duration: 6 ms
		Peak acceleration: 10X (100-20M) ms-2 (M is specimen mass in
		Kg) Number of directions: 6
		Pulses per direction: 3
		A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s
		compared with the time obtained in 4.3.6
Impact (operational)	4.6.4.2	No alarm or fault signal was given during the conditioning period
impact (operational)	4.0.4.2	or an additional 2 min.
		Conditioning:
		Impact energy: 1,9 ±0,1 J
		Hammer velocity: 1,5 ±0,13 ms ⁻¹
		Number of impacts: 1
		A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s
		compared with the time obtained in 4.3.6
Vibration, sinusoidal	4.6.4.3	No fault signal was given during the conditioning
(operational)		Conditioning:
		Frequency range: 10 to 150 Hz
		Acceleration amplitude: 5 ms ⁻² (≈0,5 g _n) Number of axes: 3
		Sweep rate: 1 octave min ⁻¹
		Number of sweep cycles: 1 per axis
		A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s
		compared with the time obtained in 4.3.6
Vibration, sinusoidal (endurance)	4.6.4.4	No fault signal was given on reconnection attributable to the endurance conditioning.
		Conditioning:
		Frequency range: 10 to 150 Hz
		Acceleration amplitude: 10 ms ⁻² (≈1,0 g _n)
		Number of axes: 3
		Sweep rate: 1 octave min ⁻¹
		Number of sweep cycles: 20 per axis
<u> </u>		



immunity (operational) during	and in EN E0120 4:2011 and No fault signal was given
compa	the conditioning. OK min ⁻¹ was not less than 30 s and did not exceed 30 s red with the time obtained in 4.3.6

Essential characteristics	Clauses in EN 54-7:2018	Regulatory classes	Performance
Operational reliability:			
Individual alarm indication	4.2.1		The visual indicator(s) are visible from a distance of 6 m in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.2		Open or short circuit failures of connection to ancillary device did not prevent the correct operation of the detector
Monitoring of detachable detectors	4.2.3	-	A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.4		It is not possible to adjust the detector settings without the use of a special tool to access into the detector or use of a code to enabling entry into the panel programming software.
On site adjustment of response behavior	4.2.5	None	The mode(s) of operation are adjustable from the Control and Indicating Equipment by use of a loop communication protocol. Access to enable mode changes is by software control of the protocol communication.
Protection against the ingress of foreign bodies	4.2.6	-	The chamber is designed so that a sphere of diameter (1,3±0,05) mm cannot pass into the sensor chamber.
Response to slowly developing fires	4.2.7		The provision of "drift compensation" (e.g. to compensate for sensor drift due to the build-up of dirt in the detector), does not lead to a significant reduction in the detectors sensitivity to slowly developing fires.
Software controlled detectors	4.2.8		The software documentation and the software design complies with the requirements of EN 54-7:2018.
Nominal activation conditions/sensitivity:			
Repeatability	4.3.1		Ratio of response values m_{max} : $m_{min} \le 1.6$ Lower response value, m_{max} : $m_{min} \ge 0.05$ dB m ⁻¹
Directional dependence	4.3.2		Ratio of response values m_{max} : $m_{min} \le 1.6$ Lower response value, m_{max} : $m_{min} \ge 0.05$ dB m ⁻¹
Reproducibility	4.3.3		Ratio of response values $m_{max}: \overline{m} \le 1.33$ Ratio of the response values $\overline{m}: m_{min} \le 1.5$ Lower response value, $m_{min} > 0.05 \text{ dB m}^{-1}$
Response delay (response time):		Threshold	
Air movement	4.4.1	-	Ratio is > 0.0625 and < 1.60 and the point smoke detector did not emit a fault nor alarm signal during the test with aerosol-free air
Dazzling	4.4.2		The specimen did not emit neither an alarm nor a fault signal and Ratio of response thresholds m_{max} : $m_{min} \le 1.6$



Tolerance to supply voltage:		
Variation in supply parameters	4.5	Ratio of response values m_{max} : $m_{min} < 1.6$ Lower response value, $m_{min} \ge 0.05 \text{ dB m}^{-1}$
Performance parameters under fire conditions:		
Fire sensitivity	4.6	Evaluated as meeting the requirements of TF2 to TF5
Durability of nominal activation conditions/Sensitivity:		
temperature resistance		
Cold (operational)	4.7.1.1	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values m_{max} : $m_{min} \le 1.6$
Dry heat (operational)	4.7.1.2	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values m_{max} : $m_{min} \le 1.6$
Humidity resistance		
Damp heat, steady-state (operational)	4.7.2.1	The specimen did not emit neither an alarm nor a fault signal and ratio of response values $m_{max}:m_{min} \le 1.6$
Damp heat, steady-state (endurance)	4.7.2.2	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max}:m_{min} \le 1.6$
Corrosion resistance		
Sulphur dioxide (SO ₂) corrosion (endurance)	4.7.3	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values m_{max} : $m_{min} \le 1.6$
Vibration resistance		
Shock (operational)	4.7.4.1	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values m_{max} : $m_{min} \le 1.6$
Impact (operational)	4.7.4.2	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values m_{max} : $m_{min} \le 1.6$
Vibration, sinusoidal (operational)	4.7.4.3	No fault signal given from the specimen during the conditioning and Ratio of response values m_{max} : m_{min} < 1.6
Vibration, sinusoidal (endurance)	4.7.4.4	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values m_{max} : m_{min} < 1.6
Electrical stability EMC immunity (operational)	4.7.5	
a) Electrostatic discharge (operational)		
b) Radiated electromagnetic fields (operational)		No alarm or fault signal given during the conditioning and Ratio of response values
c) Conducted disturbances(operational)		$m_{\text{max}}: m_{\text{min}} \leq 1.6$
d) Fast transient bursts (operational)		
e) Slow high energy voltage surge (operational)		



Essential Characteristics	Standard EN54-25:2008 + AC:2012	Performance
Performance parameters under fire conditions	4.1, 4.2.2, 5.2, 8.3.7	Pass
Response delay (response time to fire)	8.2.3, 8.2.6	Pass
Operational reliability	4.21, 4.2.3 to 4.2.7, 5.3, 5.4, 6.7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8 _b , 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5,8.3.6	Pass
Durability of operational reliability: Temperature resistance	8.3.9 _c , 8.3.10 _c , 8.3.11	Pass
Durability of operational reliability: Vibration resistance	8.3.16 _c , 8.3.17 to 8.3.19	Pass
Durability of operational reliability: Humidity resistance	8.3.12 _d , 8.3.13 _e , 8.3.14	Pass
Durability of operational reliability: Corrosion resistance	8.3.15 _c	Pass
Durability of operational reliability: Electrical stability	8.3.20	Pass

^a The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.

- b Only applicable to components required to indicate loss of communication or to transmit this information to the CIE.
- c Not applicable for CIE
- d Not applicable for CIE and smoke detectors
- e Only applicable for CIE and smoke detectors

8. Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:

Mr. David Robbins Technical Director Havant – 14.09.22

(v2)

