



**Construction Products Regulation:
EU (No) 305/2011**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

DECLARATION OF PERFORMANCE

No. E0056

1. Unique identification code of the product-type:

Model number and Description:

55000-855 XP95 Analogue Addressable DIN-Rail Protocol Translator – Single

Approved Accessories:

N/A

Harmonised Product Type(s):

Input/Output Devices

2. Intended use/es:

Fire safety

3. Manufacturer:

Apollo Fire Detectors Ltd,
36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

4. Authorised representative:

Apollo Gesellschaft für Meldetechnologie mbH
Am Anger 31
33332 Gütersloh
Deutschland

5. System(s) of AVCP

System 1

6. Harmonised Standard(s)

EN 54-18:2005

Notified Body/ies:

DBI Certification A/S (Notified Body 2531)

A HALMA COMPANY



Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

7. Declared performance

Essential Characteristics	Standard EN54-18:2005	Performance
Performance delay (response time)	5.2 ⁽¹⁾	Pass
Performance under fire conditions	5.1.4	Pass
Operational reliability	5.1.4	Pass
Durability of operational reliability: temperature resistance	5.3, 5.4	Pass
Durability of operational reliability: vibration resistance	5.8 to 5.11	Pass
Durability of operational reliability: humidity resistance	5.5, 5.6	Pass
Durability of operational reliability: corrosion resistance	5.7	Pass
Durability of operational reliability: electrical stability	5.2, 5.12	Pass
1) Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard		

8. Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

The performance of the product identified above is in conformity with the set of declared performance/s.
This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:



Mr. David Robbins
Technical Director
Havant - 21.03.2025

(v6)

