

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

55000-137 Series 65 Conventional Class CS Heat Detector

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

and produced in the manufacturing plant:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-5:2000/A1:2002 : **Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors**

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: **2019-10-08**

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

This certificate was first issued 2019-10-08



Merete Poulsen
Responsible for evaluation



Allan Laursen
Responsible for certification decision

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Annex 1

EXTENT

Type:

55000-137 Series 65 Conventional Class CS Heat Detector

Variant:

55000-137LIM (branded as Limotec)

Bases:

- 45681-200 Series 60/65 Mounting Base
- 45681-201 Series 60/65 Diode Mounting Base
- 45681-245 Series 65 Relay Mounting Base
- 45681-246 Series 65 Auxiliary Mounting Base
- 45681-247 Series 65 EOL 12 Volt Mounting Base
- 45681-248 Series 65 EOL 24 Volt Mounting Base

Note:

Meets the requirements of EN54: Part 5 at Class CS

Performance

Essential characteristics	Clauses in EN 54-5:2000	Performance
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	4.2, 4.3, 5.2 to 5.6, 5.8, 6.1, 6.2 (6.1 only Suffix S det./6.2 only Suffix R det.)	Pass
Operational reliability	4.4 to 4.11	Pass
Tolerance to supply voltage	5.7	Pass
Durability of operational reliability and response delay; temperature resistance	5.9, 5.10	Pass
Durability of operational reliability; vibration resistance	5.14 to 5.17	Pass
Durability of operational reliability; humidity resistance	5.11, 5.12	Pass
Durability of operational reliability; corrosion resistance	5.13	Pass
Durability of operational reliability; electrical stability	5.18	Pass

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.

Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
VdS	BMA 00018	3 March 2000

TECHNICAL BASIS

File Number	Title
55000-137 55000-137 45681-200 45681-201 45681-245 45681-246 45681-247 45681-248	Build Standard Build Standard Build Standard Build Standard Build Standard Build Standard Build Standard Build Standard

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.