



By Appointment to  
Her Majesty The Queen  
Manufacturers of Fire Detection & Alarm Products  
Apollo Fire Detectors Limited  
Hampshire



**Construction Products Regulation:  
EU (No) 305/2011**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

**DECLARATION OF PERFORMANCE**

**No. 0905-CPR-00186**

**1. Unique identification code of the product-type:**

**Model number and Description:**

58200-951 Analogue Addressable Waterproof Manual Call Point with Isolator

**Approved Accessories:**

N/A

**Harmonised Product Type(s):**

Manual Call Points  
Short Circuit Isolators

**2. Intended use/es:**

Fire safety

**3. Manufacturer:**

Apollo Fire Detectors Ltd,  
36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

**4. Authorised representative:**

Apollo Gesellschaft für Meldetechnologie mbH  
Am Anger 31  
33332 Gütersloh  
Deutschland

**5. System(s) of AVCP**

System 1

**6 Harmonised Standard(s)**

EN 54-11:2001 + A1:2005  
EN 54-17:2005

**Notified Body/ies:**

Intertek Testing and Certification Limited Germany (Notified Body 0905)

A HALMA COMPANY



**Apollo Fire Detectors Limited**

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

[www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

Apollo Fire Detectors Ltd. Registered in England No. 1483208

Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

## 7. Declared performance

Essential Characteristics	Standard EN 54-11:2001 + A1:2005	Performance
Nominal activation conditions/Sensitivity and Performance under fire conditions	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2,5.3	Pass
Operational reliability	4.2, 4.3.1, 4.5, 4.6, 4.7.2,4.7.3, 4.7.5, 4.8, 5.4, 5.5	Pass
Durability of operational reliability: temperature resistance	5.7, 5.8*, 5.9	Pass
Durability of operational reliability: vibration resistance	5.14 to 5.17	Pass
Durability of operational reliability: humidity resistance	5.10, 5.11*, 5.12, 5.19*	Pass
Durability of operational reliability: corrosion resistance	5.11, 5.13	Pass
Durability of operational reliability: electrical resistance	5.6, 5.18†	Pass
5.8* Outdoor Devices only 5.11*, 5.19* Outdoor Devices only 5.18† Devices with active electronic components only		

Essential Characteristics	Standard EN54-17:2005	Performance
Performance under fire conditions	5.2 <sup>(1)</sup>	Pass
Operational reliability	4	Pass
Durability of operational reliability: temperature resistance	5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	5.8	Pass
Durability of operational reliability: electrical stability	5.3,5.13	Pass
1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices		

#### 8. Online Display Location

This document can be viewed online at [www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

The performance of the product identified above is in the conformity with the set of declared performance/s.  
This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:



Mr. Karl Westhead  
Technical Director  
Havant – 19.01.2022

(v7)

