

XP95

Zone Monitor with Isolator



Product overview	
Product	Zone Monitor with Isolator
Part No.	55000-845
Digital communication	XP95 (Discovery and CoreProtocol compatible)

Compliance			
CE	LPCB	VdS	
FG	((()	GOST-R	

Product information

The XP95 Zone Monitor with Isolator powers and controls the operation of a zone of up to 20 Orbis/Series 65 Apollo fire detectors from the Apollo loop and is for indoor use only.

Features

The XP95 Zone Monitor with Isolator returns a preset analogue value when all detectors on the zone are in quiescent state. A different value is returned when a detector changes to the alarm state. The Zone Monitor with Isolator latches in the alarm state.

The Zone Monitor with Isolator is fitted with a bi-directional short circuit isolator and will be unaffected by loop shortcircuits on either the loop input or loop output.

Two LEDs, one red and one yellow, are visible through the front cover of the enclosure. The red LED is illuminated to indicate that a fire alarm condition has been detected on the zone wiring. The yellow LED is illuminated whenever the built-in isolator has sensed a short-circuit loop fault.

Technical data

All data is supplied subject to change without notice. Specifications are typical at 24 V, +25°C and 50% RH unless otherwise stated.

17 V-28 V dc with protocol Supply Voltage

pulses of 5 - 9 V dc.

Zone voltage (Loop voltage 22 V) 19 V ± 1 V

(Loop voltage < 22 V) Loop voltage - 1.5 V

Maximum current consumption at 24V (5.1 $k\Omega$ EOL):

Switch-on surge, 150 ms max 3.5 mA

Quiescent 4 mA plus detector load

50 uF

Alarm 11 mA (19 mA when increased

current enabled)

Short circuit 11 mA

End-of-line resistor value 5.1 k ± 5% 1/3 W Stabilisation time on power-up 4 seconds

Maximum capacitor on zone

terminals

Operating temperature -20 °C to +70 °C 0% to 95% RH Humidity (no condensation)

Standards and Approvals CPR, LPCB, VdS, VNIIPO, FG,

CCCf and CCMG

IP Rating

150 mm wide x 90 mm height Dimensions

x 48 mm deep

Weight

Materials White flame retardant

polycarbonate

EMC Directive 2014/30/EU

The XP95 Zone Monitor with Isolator complies with the essential requirements of the EMC Directive 2014/30/EU, provided that it is used as described in this datasheet.

A copy of the Declaration of Conformity is available from the Apollo website: www.apollo-fire.co.uk

Conformity of the XP95 Zone Monitor with Isolator with the EMC Directive, does not confer compliance with the directive on any apparatus or systems connected to it.

Construction Products Regulation 305/2011/EU

The XP95 Zone Monitor with Isolator complies with the essential requirements of the Construction Products Regulation 305/2011/EU.

A copy of the Declaration of Performance is available from the Apollo website: www.apollo-fire.co.uk

Hampshire, P09 1JR, UK.

Tel: +44 (0)23 9249 2412 Fax: +44 (0)23 9249 2754

Email: sales@apollo-fire.com Web: www.apollo-fire.co.uk

All information in this document is given in good faith but Apollo Fire Detectors Ltd cannot be held responsible for any omissions or errors. The company reserves the right to change the specifications of products at any time and without prior notice





















