



Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

**B
E
LAC**
003-PROD
ISO/IEC 17065

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1134-CPR-077

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the products Construction Products Regulation or CPR), this certificate applies to the construction product

Fire detection control panel with power supply equipment Limotec MD2400

with the variants and the performances listed in annex of this certificate and for the intended use:
Fire safety

manufactured by or for

**Limotec NV
Bosstraat 21
8570 Vichte
Belgium**

and produced in the manufacturing plant

**Limotec NV
Bosstraat 21
8570 Vichte
Belgium**

This certificate attests that all provisions concerning the assessment and the verification of constancy performance and the performances described in Annex ZA of the standard(s):

**EN 54-2:1997/A1:2006
EN 54-4:1997/A1:2002/A2:2006**

under system 1 are applied and that

the products fulfil all prescribed requirements set out above.

This certificate was first issued on 2014-01-02 and remains valid as a long time as the testing methods and/or for the control of the production in factory included in the harmonized standard, used to evaluate the performances of the declared characteristics, do not change and as neither the product, nor the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

Brussels, 20 November 2025

Marie-Magdalene Van Damme
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be



Annex 1 to the CERTIFICATE CONSTANCY OF PERFORMANCE

1134-CPR-077

Variants of the Limotec MD2400

Fire detection control panel with power supply equipment
Limotec MD2400 (4, 8 or 16 loop)

Power supply component
Limotec T095072 (supply monitor)
Meanwell RSP-320-36 (power supply)

Product/System component
Limotec T095066 (DC/DC converter)
Limotec T240004 (user console)
Limotec T240008 (loop card)
Limotec T240016 (bus card)
Limotec T240018 (relay card)
Limotec T240022 (switch)
Limotec T240074 (loop card high power)
Limotec T240077 (network card)
Limotec T240080 (processor card)
Limotec T240092 (user console)

Housing
Limotec 245040XP1
Variants: 245040XP2
245040XP2A
245080XP2
245080XP2A
245140XP4
245160XP4

Repeater
Limotec T240092

Brussels, 20 November 2025


Marie-Magdalene
Vanhaezebrouck
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be



Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

**B
E
LAC**
003-PROD
ISO/IEC 17065

Annex 2 to the CERTIFICATE CONSTANCY OF PERFORMANCE

1134-CPR-077

Certified with the following options from the EN 54-2:1997/A1:2006

7.8	Output to fire alarm devices
7.11	Delays to outputs
8.3	Fault signals from points
9.5	Disablement of addressable points
10	Test conditions

Brussels, 20 November 2025


Marie-Magdalene
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be