



CERTIFICATE

B - 9077 - FD - K 510 - version e

We certify that the fire detection component:

HEAT DETECTORS:

APOLLO ORB-HT-11001-APO, APOLLO ORB-HT-11002-APO, APOLLO ORB-HT-11003-APO,
APOLLO ORB-HT-11004-APO, APOLLO ORB-HT-11005-APO, APOLLO ORB-HT-11006-APO,
APOLLO ORB-HT-11166-APO

Variants: APOLLO ORB-HT-11013-APO, APOLLO ORB-HT-11014-APO, APOLLO ORB-HT-
11015-APO, APOLLO ORB-HT-11016-APO, APOLLO ORB-HT-11017-APO, APOLLO ORB-HT-
11018-APO

Base: ORB-RB-10004-APO, ORB-DB-00003-APO, ORB-MB-00001-APO, ORB-MB-00002-APO

Manufactured at Havant,
United Kingdom

complies with the following specifications:

BOSEC Mark Rules:

Administrative and Legal Clauses & Certification rules Products ;

EN 54-5:2000/A1:2002

EN 54-18:2005

based upon the test report of the laboratories ANPI & Certificate(s) of Constancy of Performance (CPR):

BFS/REDI/148 - 2004.07.19, add. 1 - 2012.08.01 & 2531-CPR-CSP10954, 2531-CPR-CSP10959,
2531-CPR-CSP10960, 2531-CPR-CSP10961, 2531-CPR-CSP10962, 2531-CPR-CSP10963, 2531-
CPR-CSP10966, 2531-CPR-CSP11164

*This certificate is only valid if the products are marked with the **BOSEC** label.*

The company

Apollo Fire Detectors Ltd

36 Brookside Road

Havant

Hampshire PO9 1JR

United Kingdom

*is authorised to use the brand **BOSEC** on the above mentioned components. An instruction manual shall be provided with each detector*

**The certificate is granted subject to the
BOSEC brand committee and ANPI terms
and conditions and is valid until**

31 August 2022

signed on behalf of **ANPI**
Brussels, 10 February 2020

Secretary-General
F. Duillet

asbl **ANPI** vzw - Association Nationale pour la Protection contre l'Incendie et l'Intrusion

Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve

Tél: +32 10 47 52 11 Fax: +32 10 47 52 70 cert@anpi.be www.anpi.be



This certificate and the annexes may only be copied completely and without any alteration.

CERT-PROD 017 CERTIFICATION DRAW UP F ATTEST 001 CERTIFICATE BOSEC F D P L F N V6