

Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve - **BELGIUM**
Tel : 32 2 234 36 10 Fax: 32 2 234 36 17 Email : cert@anpi.be

EC-CERTIFICATE OF CONFORMITY

1134 - CPD - 106

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Control and Indicating Equipment

LIMOTEC MD644

Integrated Power Supply Equipment

Fixed fire fighting systems – Fire Detection and Fire alarm Systems

placed on the market by

**LIMOTEC nv.
Bosstraat, 21
B – 8570 VICHTE
BELGIUM**

and produced in the factory

**LIMOTEC nv.
Bosstraat, 21
B – 8570 VICHTE
BELGIUM**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body **ANPI** has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard (*resp. in*)

EN 54-2: 1997/A1: 2006

EN 54-4: 1997/A1: 2002 + A2: 2006

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on **29-04-2011** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Brussels, the 29th of April, 2011

Ing. M. VANDENDOREN
Secrétaire Général of ANPI



ANNEX N° 1 to EC-CERTIFICATE OF CONFORMITY

1134 - CPD - 106

The Control and Indicating Equipment LIMOTEC MD644 include also the following optional functions of the EN 54-2/A1:2006

<i>Options with requirements :</i>	
7.8	Output to fire alarm devices (output to C)


Ing. M. VANDENDOREN
Secrétaire Général of ANPI