



By Appointment to
Her Majesty The Queen
Manufacturers of Fire Detection & Alarm Products
Apollo Fire Detectors Limited
Hampshire



**Construction Products Regulation:
EU (No) 305/2011**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

DECLARATION OF PERFORMANCE

No. D0024

1. Unique identification code of the product-type:

Model number and Description:

RW1700-051APO – REACH Input Device using Radio Links

Approved Accessories:

n/a

Harmonised Product Type(s):

IO Devices
Components using radio links

2. Intended use/es:

Fire safety

3. Manufacturer:

Apollo Fire Detectors Ltd,
36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

4. Authorised representative:

Apollo Gesellschaft für Meldetechnologie mbH
Am Anger 31
33332 Gütersloh
Deutschland

5. System(s) of AVCP

System 1

6 Harmonised Standard(s)

EN 54-18:2005
EN 54-25:2008 + AC:2012

Notified Body/ies:

IMQ ISTITUTO ITALIANO DEL MARCHIO DI QUALITÀ S.P.A. (Notified Body No. 0051)

A HALMA COMPANY



Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

7. Declared performance

Essential Characteristics	Standard EN54-18:2005	Performance
Performance delay (response time)	5.2 ⁽¹⁾	Pass
Performance under fire conditions	5.1.4	Pass
Operational reliability	5.1.4	Pass
Durability of operational reliability: temperature resistance	5.3, 5.4	Pass
Durability of operational reliability: vibration resistance	5.8 to 5.11	Pass
Durability of operational reliability: humidity resistance	5.5, 5.6	Pass
Durability of operational reliability: corrosion resistance	5.7	Pass
Durability of operational reliability: electrical stability	5.2, 5.12	Pass
1) Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard		

Essential Characteristics	Standard EN54-25:2008 + AC:2012	Performance
Performance parameters under fire conditions	4.1, 4.2.2, 5.2, 8.3.7	Pass
Response delay (response time to fire)	8.2.3, 8.2.6	Pass
Operational reliability	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6.7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8 _b , 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6	Pass
Durability of operational reliability: Temperature resistance	8.3.9 _c , 8.3.10 _c , 8.3.11	Pass
Durability of operational reliability: Vibration resistance	8.3.16 _c , 8.3.17 to 8.3.19	Pass
Durability of operational reliability: Humidity resistance	8.3.12 _d , 8.3.13 _e , 8.3.14	Pass
Durability of operational reliability: Corrosion resistance	8.3.15 _c	Pass
Durability of operational reliability: Electrical stability	8.3.20	Pass
<p>^a The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.</p> <p>^b Only applicable to components required to indicate loss of communication or to transmit this information to the CIE.</p> <p>^c Not applicable for CIE</p> <p>^d Not applicable for CIE and smoke detectors</p> <p>^e Only applicable for CIE and smoke detectors</p>		

8. Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

The performance of the product identified above is in the conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:



Mr. Karl Westhead
 Technical Director
 Havant – 08.12.2021

(v1)

