

DECLARATION OF PERFORMANCE

DoP2021-0006

According to the Construction Products Regulation:

(CE) EU no. 305/2011

and /or

(UKCA) 2011 as amended by:

Construction Products (Amendment etc.) (EU Exit) Regulations 2019

Construction Products (Amendment etc.) (EU Exit) Regulations 2020

1	Unique Identification code of the product(s)	STX2410-E STX2410-H BATT_BOX-65
2	Type, batch or serial number or any other element allowing identification of the construction product	Products are provided a batch manufacturing code based on date format
3	Intended use or uses of the construction product	Battery backed up Power supply for Fire Detection, signaling and indication equipment
4	Name, registered trade name or registered trade mark and contact address of the manufacturer	Elmdene International Limited 3 Keel Close, Interchange Park, Portsmouth, PO3 5QD, UK
5	Where applicable, name and contact address of the authorised representative	Not applicable
6	System or systems of assessment and verification of constancy of performance	System 1 testing
7 (EU)	According to the Construction Products Regulation EU no. 305/2011	
EU	Name and Identification of notified body	UL International (Netherlands) B.V., Westervoortsedijk 60, 6827 AT ARNHEM, (NL) Notified Body No.: CE 2821
EU	Date of compliance and continuing approval	01 January 2022
EU	Under System	Level 1 - Factory Production Control
EU	CPR EC Certificate	2821-CPR-0154
EU	CPR UL EC Certificate (NC25138-D3)	UL-EU-01115-CPR - 23/08/2019
7(UK)	According to the Construction Products Regulation 2011 as amended: Construction Products (Amendment etc.) (EU Exit) Regulations 2019 Construction Products (Amendment etc.) (EU Exit) Regulations 2020	
UK	Name and Identification of notified body	UL International (UK) LTD, 220 Cygnet Court, Centre Park, Warrington, WA1 1PP (UK) Notified Body No.: UKCA 0843
UK	Date of compliance and continuing approval	01 January 2022
UK	Under System	Level 1 - Factory Production Control
UK	UKCA Certificate	0843-CPR-1004
8	In case of declaration of performance concerning a construction product for which European Technical Assessment has been issued	Not applicable.

9. Declared performance

Essential Characteristics	Performance	Standard
Operational reliability		
4 General Requirements	Pass	EN 54-4:1997 + A1:2002 + A2:2006
5 Functions	Pass	EN 54-4:1997 + A1:2002 + A2:2006
6 Materials, design and manufacture	Pass	EN 54-4:1997 + A1:2002 + A2:2006
7 Documentation	Pass	EN 54-4:1997 + A1:2002 + A2:2006
8 Marking	Pass	EN 54-4:1997 + A1:2002 + A2:2006
Performance of Power Supply		

Essential Characteristics	Performance	Standard
4 General Requirements	Pass	EN 54-4:1997 + A1:2002 + A2:2006
5 Functions	Pass	EN 54-4:1997 + A1:2002 + A2:2006
6 Materials, design and manufacture	Pass	EN 54-4:1997 + A1:2002 + A2:2006
Durability of operational reliability: temperature resistance		
9.5 Cold (Operational)	Pass	EN 54-4:1997 + A1:2002 + A2:2006
Durability of operational reliability: vibration resistance		
9.7 Impact (operational)	Pass	EN 54-4:1997 + A1:2002 + A2:2006
9.8 Vibration, sinusoidal (operational)	Pass	EN 54-4:1997 + A1:2002 + A2:2006
9.15 Vibration, sinusoidal (endurance)	Pass	EN 54-4:1997 + A1:2002 + A2:2006
Durability of operational reliability: electrical stability		
9.9 Electromagnetic Compatibility (EMC), Immunity Tests	Pass	EN 54-4:1997 + A1:2002 + A2:2006
Durability of operational reliability: vibration resistance		
9.7 Impact (operational)	Pass	EN 54-4:1997 + A1:2002 + A2:2006
Durability of operational reliability: humidity resistance		
9.6 Damp heat, steady state (operational)	Pass	EN 54-4:1997 + A1:2002 + A2:2006
9.14 Damp heat, steady state (endurance)	Pass	EN 54-4:1997 + A1:2002 + A2:2006

10. The performance of the Product Identified in (1), (2) above, is in conformity with the declared performance in (9). This declaration of Performance is issued under the sole responsibility of the manufacturer identified in (4) For and on behalf of Elmdene International Ltd

Steve Grenyer - Engineering Manager
Portsmouth - United Kingdom

Date: 04/01/2022